

Data Sheet CODESYS Control for PLCnext SL

CODESYS Control for PLCnext SL is an adapted CODESYS Control runtime system for the Phoenix PLCnext controllers AXC F 2152 and AXC F 1152.

Product description

CODESYS Control for PLCnext SL is a CODESYS Control runtime system for the Phoenix PLCnext Controllers AXC F 2152 and AXC F 1152 (see https://www.phoenixcontact.com/). The package includes the option to use the AXIO extension modules.

To install the product on the Linux OS via the CODESYS Development System, use the the included CODESYS Deploy Tool plug-in. After each restart the runtime system will be started automatically. If no valid full license can be found, CODESYS Control runs for two hours without functional limitations before shut down.

After installing the runtime environment, the PLCnext controller can be programmed as a PLC with the CODESYS Development System.

Benefits

- Suitable for controlling tasks in all automation fields
- Comprehensive engineering solution with the free CODESYS Development System (V3), including extensive visualization options
- Efficient engineering with the products of the CODESYS Professional Developer Edition (code management via link to Apache Subversion, static code analysis, runtime measurement on the PLC, comprehensive test automation, methodical application development with UML diagrams)
- Compatible with additional add-ons and products from the CODESYS Store

Interfaces

The runtime package includes the following interfaces:

- Axioline-I/O-System for AXIO I/O-Module support
- CODESYS OPC UA Server

Visualization

The runtime package includes the following visualization products:

• CODESYS WebVisu

Fieldbus support

The runtime package includes the following fieldbus products:

- CODESYS CANopen Master / Slave
- CODESYS EtherCAT Master
- CODESYS EtherNet/IP Scanner / Adapter
- CODESYS Modbus TCP Master / Slave
- CODESYS Modbus Serial Master / Slave
- CODESYS J1939
- CODESYS PROFINET Controller / Device

Options

The runtime package can be extended by the following products:

- CODESYS Control for PLCnext Multicore SL
- CODESYS BACnet SL
- · CODESYS KNX SL
- CODESYS Redundancy SL
- CODESYS SoftMotion
- CODESYS SoftMotion CNC + Robotics

General information

Supplier:

CODESYS GmbH Memminger Strasse 151 87439 Kempten Germany

Support:

Technical support is not included with this product. To receive technical support, please purchase a CODESYS Support Ticket.

https://support.codesys.com

Item:

CODESYS Control for PLCnext SL

Item number:

2302000033

Sales/Source of supply:

CODESYS Store

https://store.codesys.com

Included in delivery:

- Package for the CODESYS Development System including CODESYS Control, license agreement, online help and device description
- License Key

System requirements and restrictions

Programming System	CODESYS Development System V3.5.17.0 or higher
Supported Platforms/ Devices	Phoenix AXC F 2152
	Phoenix AXC F 1152
	Note: Use the tool "Device Reader" to find out the
	supported features of your device (free of charge
	component of CODESYS Development System).
Additional Requirements	PLCnext Firmware:
	 Minimum version 2023: >= 2023.0
	 Minimum version 2024: >= 2024.0.6
	∘ only LTS versions are supported

- Dynamic libraries required by the CODESYS Control Runtime binary:
 - ∘ libm.so.6
 - ∘ libpthread.so.0
 - ∘ libdl.so.2
 - ∘ librt.so.1
 - o libc.so.6
 - ∘ libgcc_s.so.1

Restrictions

- Ethernet ports are not physically separated (integrated switch)
- Not released for use in containers or virtual machines (VMs)!

Licensing



Application based license: The CODESYS Control SL runtime system can be licensed with an application-based license.

The license is activated on a software-based license container (soft container) that is permanently bound to the device. Alternatively, the license can be stored on a CODESYS key (USB dongle).

Note: In demo mode, the software runs for two hours without a license. After that, a manual restart is required.

Note: Technical specifications are subject to change. Errors and omissions excepted. The content of the current online version of this document applies.

Creation date: 2025-04-07